



Generated By: Bradley Lynch Phone: (225) 603-6548
 AdvantaClean of Metro Baton Rouge
 11725 Cloverland Ct Suite B
 Baton Rouge, LA 70809
 (225) 369-5228

Service Address

**WN Dentistry
 7931 Jefferson Hwy
 Baton Rouge, LA 70809**

QTY	Units	Product	Description
Duct Production			
1	Each	AD - Summary - Commercial Duct	Summary - Commercial Duct Cleaning

Introduction:

AdvantaClean performs Air Duct and HVAC Systems cleaning in accordance with the only recognized standard for air duct cleaning, the National Air Duct Cleaners Association (NADCA) ACR-2013.

Scope of work includes cleaning all interior components of the air conveyance system (i.e. sheet metal ducts, rigid fiberglass duct board, and flex duct). Cleaning will properly remove lint, hair, fungi, dirt and other foreign materials and residues. The cleaning procedures shall be accompanied by the use of specialized equipment, (i.e., high efficiency vacuum system utilizing HEPA filters, high pressure washers, duct brushes, etc.), as required. Access openings may be cut in the ducts as required for proper cleaning at various points of the duct system for physical and mechanical entry.

Surfaces of grills and diffusers will be treated with a non-toxic, disinfecting solution.

HEPA vacuum Air handler(s) shall be cleaned, to include blowers, fan housing, blades, vanes, shafts, baffles, and drive assemblies. All interior components of the air handler shall be cleaned in-place. All mechanical or machined components shall be maintained for corrosion by removing loose rust and scale.

Anti-Microbial Treatment:

Following the completion of the mechanical cleaning process, a residual antimicrobial treatment shall be applied to the interior of the ductwork. Anti-microbial solutions will be applied per manufacturer's specifications. (disinfect with Shock Wave hospital grade disinfectant)